

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-11921
Name of Facility: Curry, Lamar Louise Md.
Address: 15750 SW 47 Street
City, Zip: Miami 33185

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: M-DCSB Food and Nutrition
Person In Charge: Jean-Rachelle Baril Phone: (305)222-2794
PIC Email: rbaril@dadeschools.net

Inspection Information

Purpose: Routine
Inspection Date: 7/26/2021

Begin Time: 02:05 PM
End Time: 03:10 PM

Additional Information

FEMALES 93
MALES 86

CENSUS 179

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	OUT	11. Group Toilet Rooms	IN	21. Pest Control
IN 1. School Site	IN	12. Toilet Facilities		SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN	13. Handwashing Facilities	IN	22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN	14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN	15. Shower Facilities	NA	23. Sanitizers
IN 4. Construction	IN	16. Showers Water Temperatures	NA	24. Changing Station & Mats
IN 5. Maintenance & Repair		WATER SUPPLY	NA	25. Hand Sink
IN 6. Lighting Standards	IN	17. Approved Source	NA	26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN	18. Drinking Fountains		ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation		LIQUID WASTE & WASTE WATER	NA	27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN	19. Sewage Disposal		DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN	20. Solid Waste	NA	28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation		PEST CONTROL	IN	29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Notes: School open for summer school.
Inspection conducted during COVID-19 pandemic.

Email Address(es): rbaril@dadeschools.net;
jboue@dadeschools.net;
guillermocortez@dadeschools.net

Violations Comments

Violation #11. Group Toilet Rooms
Repair ceiling hair line cracks inside #414 Female restroom & #413 Male restroom.
Repair out-of-order handwashing sink faucets inside:
-#223 Female restroom (handwashing sink on far left)
-#323 Female restroom (handwashing sink on far left)
-#414 Female restroom handicap stall
- #434C Male locker room restroom handicap stall
-#431E Female locker room restroom handicap stall

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Inspection Conducted By: Venus Fernandez (82515)
Inspector Contact Number: Work: (305) 623-3516 ex.
Print Client Name: Guillermo Cortez-AP
Date: 7/26/2021

Inspector Signature:

Handwritten signature of Venus Fernandez.

Client Signature:

Handwritten signature of Guillermo Cortez-AP.